

WATER BOY INC. QUALITY REPORT

INTRODUCTION

Your bottled water meets all federal and state health standards. FDA regulates bottled water as a food product whereas EPA regulates tap water as provided by water utilities. Standards of quality enacted by the FDA for bottled water must be as protective of the public health as EPA's standards (known as Maximum Contaminant Levels) for tap water. Ensuring the safety of the water is our primary objective in providing our product to the consumer.

OUR SOURCE FOR OUR WATER

Water Boy, Inc. Spring Water, our own brand, comes from Bear Hollow Springs, located near Lake Placid, Florida. This water source begins as rain water that permeates through quartz sand and various geologic layers resulting in naturally pure water as indicated by its very low total dissolved solids.

Water Boy Inc. Drinking Water is purified water. It originates from the County Reservoir located in eastern Manatee County.

Water Boy Inc. Distilled Water is pure H₂O, also originating from the County Reservoir.

Water Boy, Inc.'s bottling facility tests our sources regularly to verify that they are of extremely high quality.

HOW WATER BOY BOTTLED WATER IS PREPARED

Bottled water is protected by a multi-barrier approach which may include steps such as source protection and monitoring, and treatment such as reverse osmosis, micron filtration, distillation, ozonation, the application of ultraviolet light or other appropriate processing measures. Bottled water products labeled as spring water, well water, artesian water and mineral water must come from protected sources which are monitored frequently. Bottled water may also come from treated municipal supplies. IBWA member companies using municipal sources employ processing methods, such as reverse osmosis, micron filtration, distillation and/or ozonation to remove any chemical and microbiological contaminants, including Cryptosporidium. IBWA members, regardless of their source type, use a variety of practices to ensure the safety and high quality of their products.

Multiple stages of filtration include carbon filtration, micron filtration and particulate filtration to remove sediment and suspended particles. Double pass reverse osmosis, a process that removes nearly all of the salts or minerals in the source water is then used. It works by forcing the water through a semipermeable membrane twice (the water passes through but the minerals do not).

For our Water Boy Inc. Distilled Water, the water is heated to produce steam. The minerals are left behind and the steam is condensed for a pure, mineral-free distilled product.

Water Boy Inc. Drinking Water is purified through a rigorous multi-step process using reverse osmosis and ozonation. These processes remove all chemical and dissolved solids, leaving a pure, clean, refreshing tasting water with no after taste. The sodium level in the Water Boy, Inc. Drinking Water is less than 1 milligram per 8 ounce serving.

Water Boy Inc. Spring Water comes from our protected spring and is low in minerals, contains less than 0.5 milligrams of sodium per 8 ounces serving, and has that delicious spring water taste. It is trucked to our bottling plant, then micron filtered and ozonated.

All of our bottled water products are ozonated. We use ozone instead of chlorine because it leaves no residual and it does not cause a taste and odor problem. Ozone is oxygen (O₃ to be exact) which is bubbled through the water just before it goes into a clean, sanitized bottle. Within a few hours after the bottle has been filled and capped, the ozone dissipates or converts back to the same form of oxygen that we breathe (O₂).

TABLE 1: WATERBOY, INC. SPECIFIC MINERAL ANALYSIS

General Mineral Analysis	Distilled Water	Drinking Water	Spring Water
Bicarbonate	N/D	N/D	18mg/L
Calcium	N/D	N/D	5.1mg/L
Chloride	N/D	N/D	4mg/L
Fluoride	N/D	N/D	0.2mg/L
Magnesium	N/D	N/D	0.63mg/L
Sodium	N/D	1.2mg/L	2.8mg/L
Sulfate	N/D	N/D	1.3mg/L
Total Dissolved Solids	1mg/L	7mg/L	53mg/L
Total Hardness	N/D	N/D	15mg/L
Alkalinity	N/D	N/D	15mg/L
Conductivity	N/D	N/D	52mg/L
PH	6.1-7.0	6.5-7.2	6.5-8.5

*N/D indicates "None Detected"

OUR COMPANY'S WATER TESTING

Our company regularly tests for organic chemicals and inorganic chemicals that are regulated by the FDA. As an extra safeguard we also test for unregulated contaminants. No contaminant was detected above FDA's limits in our testing as demonstrated by Table 2. There have been no violations of any FDA Standard of Quality.

TABLE 2: WATERBOY PRODUCT ANALYSIS (All results reported in mg/L except as noted)

Product>	Distilled Water	Drinking Water	Spring Water	Detection Limit	FDA SOQ
<u>Inorganic Chemicals</u>					
Antimony (2)	N/D	N/D	N/D	0.001	0.006
Arsenic	N/D	N/D	N/D	0.002	0.05
Barium	N/D	N/D	N/D	0.1	2
Beryllium (2)	N/D	N/D	N/D	0.001	0.004
Cadmium	N/D	N/D	N/D	0.001	0.005
Chromium	N/D	N/D	N/D	0.05	0.1
Cyanide (2)	N/D	N/D	N/D	0.05	0.1
Fluoride	N/D	N/D	N/D	0.5	2 / 1.3
Lead	N/D	N/D	N/D	0.001	0.005
Mercury	N/D	N/D	N/D	0.0002	0.002
Nickel (2)	N/D	N/D	N/D	0.05	0.1
Nitrate-N	N/D	N/D	N/D	0.1	10
Nitrite-N	N/D	N/D	N/D	0.01	1
Total Nitrate + Nitrite	N/D	N/D	N/D	0.1	10
Selenium	N/D	N/D	N/D	0.01	0.05
Thallium (2)	N/D	N/D	N/D	0.0005	0.002
<u>Secondary Inorganic Parameters</u>					
Aluminum	N/D	N/D	N/D	0.05	0.2
Chloride	N/D	N/D	2.4	0.5	250
Copper	N/D	N/D	N/D	0.01	1
Iron	N/D	N/D	0.07	0.01	0.3
Manganese	N/D	N/D	N/D	0.001	0.05
Silver	N/D	N/D	N/D	0.005	0.1
Sulfate	N/D	N/D	N/D	2	250
Total Dissolved Solids (TDS)	1	7	53	1	500
Zinc	N/D	N/D	N/D	0.1	5
<u>Volatile Organic Chemicals</u>					
1,1,1-Trichloroethane	N/D	N/D	N/D	0.0005	0.2
1,1,2-Trichloroethane	N/D	N/D	N/D	0.0005	0.005
1,1-Dichloroethylene	N/D	N/D	N/D	0.0005	0.007
1,2,4-Trichlorobenzene	N/D	N/D	N/D	0.0005	0.07
1,2-Dichloroethane	N/D	N/D	N/D	0.0005	0.005
1,2-Dichloropropane	N/D	N/D	N/D	0.0005	0.005
Benzene	N/D	N/D	N/D	0.0005	0.005
Carbon tetrachloride	N/D	N/D	N/D	0.0005	0.005
cis-1,2-Dichloroethylene	N/D	N/D	N/D	0.0005	0.07
trans-1,2-Dichloroethylene	N/D	N/D	N/D	0.0005	0.1
Ethylbenzene	N/D	N/D	N/D	0.0005	0.7
Methylene chloride (Dichloromethane)	N/D	N/D	N/D	0.0005	0.005
Methyl tertiary butyl ether (MTBE)	N/D	N/D	N/D	0.0005	No standard
Monochlorobenzene	N/D	N/D	N/D	0.0005	0.1
o-Dichlorobenzene	N/D	N/D	N/D	0.0005	0.6
p-Dichlorobenzene	N/D	N/D	N/D	0.0005	0.075
Styrene	N/D	N/D	N/D	0.0005	0.1
Tetrachloroethylene	N/D	N/D	N/D	0.0005	0.005

N/D = Not detected

Product>	Distilled Water	Drinking Water	Spring Water	Detection Limit	FDA SOQ
<u>Volatile Organic Chemicals</u>					
<u>(Cont'd.)</u>					
Toluene	N/D	N/D	N/D	0.0005	1
Trichloroethylene	N/D	N/D	N/D	0.0005	0.005
Vinyl chloride	N/D	N/D	N/D	0.0005	0.002
Xylenes (total)	N/D	N/D	N/D	0.0005	10
Bromodichloromethane	N/D	N/D	N/D	0.0005	No standard
Chlorodibromomethane	N/D	N/D	N/D	0.0005	No standard
Chloroform	N/D	N/D	N/D	0.0005	No standard
Bromoform	N/D	N/D	N/D	0.0005	No standard
Total Trihalomethanes	N/D	N/D	N/D	0.0005	0.1
<u>Semivolatile Organic Chemicals</u>					
Benzo(a)pyrene	N/D	N/D	N/D	0.0001	0.0002
Di(2-ethylhexyl)adipate	N/D	N/D	N/D	0.05	0.4
Di(2-ethylhexyl)phthalate	N/D	N/D	N/D	0.001	0.006
Hexachlorobenzene	N/D	N/D	N/D	0.0005	0.001
Hexachlorocyclopentadiene	N/D	N/D	N/D	0.005	0.05
Total Recoverable Phenolics	N/D	N/D	N/D	0.0005	0.001
<u>Synthetic Organic Chemicals</u>					
2,4,5-TP (Silvex)	N/D	N/D	N/D	0.001	0.05
2,4-D (Dichlorophenoxy acetic acid)	N/D	N/D	N/D	0.005	0.07
Alachlor	N/D	N/D	N/D	0.0005	0.002
Aldicarb	N/D	N/D	N/D	0.0005	0.003
Aldicarb sulfone	N/D	N/D	N/D	0.0005	0.003
Aldicarb sulfoxide	N/D	N/D	N/D	0.0005	0.004
Atrazine	N/D	N/D	N/D	0.0005	0.003
Carbofuran	N/D	N/D	N/D	0.001	0.04
Chlordane	N/D	N/D	N/D	0.0005	0.002
Dalapon	N/D	N/D	N/D	0.05	0.2
Dibromochloropropane (DBCP)	N/D	N/D	N/D	0.0005	0.0002
Dinoseb	N/D	N/D	N/D	0.001	0.007
Dioxin (2,3,7,8-TCDD)	N/D	N/D	N/D	0.5x10 ⁻⁸	3x10 ⁻⁸
Diquat	N/D	N/D	N/D	0.005	0.02
Endothall	N/D	N/D	N/D	0.005	0.1
Endrin	N/D	N/D	N/D	0.00005	0.0002
Ethylene dibromide	N/D	N/D	N/D	0.00001	0.00005
Glyphosate	N/D	N/D	N/D	0.05	0.7
Heptachlor	N/D	N/D	N/D	0.00005	0.0004
Heptachlor epoxide	N/D	N/D	N/D	0.00005	0.0002
Lindane	N/D	N/D	N/D	0.00005	0.0002
Methoxychlor	N/D	N/D	N/D	0.005	0.04
Oxamyl (vydate)	N/D	N/D	N/D	0.05	0.2
Pentachlorophenol	N/D	N/D	N/D	0.0005	0.001
Picloram	N/D	N/D	N/D	0.01	0.5
Polychlorinated biphenyls (PCBs)	N/D	N/D	N/D	0.00005	0.0005
Simazine	N/D	N/D	N/D	0.0005	0.004
Toxaphene	N/D	N/D	N/D	0.0001	0.003

*N/D indicates "None Detected"

Product>	Distilled Water	Drinking Water	Spring Water	Detection Limit	FDA SOQ
<u>Water Properties</u>					
Color	N/D	N/D	N/D	1 Unit	5 Units
Turbidity	N/D	N/D	0.2	0.1 NTU	0.5 NTU
pH	6.1	6.9	7.8	0.01 SU	6.5-8.5 SU
Odor	N/D	N/D	N/D	1 T.O.N.	3 T.O.N.
Chlorine	N/D	N/D	N/D	0.01	No standard
<u>Radiological Contaminants</u>					
Gross alpha	N/D	N/D	N/D	1 pCi/L	15 pCi/L
Gross beta	N/D	N/D	N/D	5 pCi/L	50 pCi/L
<u>Microbiological Contaminants</u>					
Total Coliform	N/D	N/D	N/D	Presence	Not detected
Heterotrophic Plate Count	N/D	N/D	N/D	1 CFU	No standard
<i>Cryptosporidium parvum</i>	N/D	N/D	N/D	Presence	No standard
<i>Giardia lamblia</i>	N/D	N/D	N/D	Presence	No standard
<u>Unregulated Contaminants</u>					
Chloroform	N/D	N/D	N/D	0.0005	No standard
Bromodichloromethane	N/D	N/D	N/D	0.0005	No standard
Chlorodibromomethane	N/D	N/D	N/D	0.0005	No standard
Bromoform	N/D	N/D	N/D	0.0005	No standard
Dibromomethane	N/D	N/D	N/D	0.0005	No standard
m-Dichlorobenzene	N/D	N/D	N/D	0.0005	No standard
1,1-Dichloropropene	N/D	N/D	N/D	0.0005	No standard
1,1-Dichloroethane	N/D	N/D	N/D	0.0005	No standard
1,1,2,2-Tetrachloroethane	N/D	N/D	N/D	0.0005	No standard
1,3-Dichloropropane	N/D	N/D	N/D	0.0005	No standard
Chloromethane	N/D	N/D	N/D	0.0005	No standard
Bromomethane	N/D	N/D	N/D	0.0005	No standard
1,2,3-Trichloropropane	N/D	N/D	N/D	0.0005	No standard
1,1,1,2-Tetrachloroethane	N/D	N/D	N/D	0.0005	No standard
Chloroethane	N/D	N/D	N/D	0.0005	No standard
2,2-Dichloropropane	N/D	N/D	N/D	0.0005	No standard
o-Chlorotoluene	N/D	N/D	N/D	0.0005	No standard
p-Chlorotoluene	N/D	N/D	N/D	0.0005	No standard
Bromobenzene	N/D	N/D	N/D	0.0005	No standard
1,3-Dichloropropene	N/D	N/D	N/D	0.0005	No standard
1,2,4-Trimethylbenzene	N/D	N/D	N/D	0.0005	No standard
1,2,3-Trichlorobenzene	N/D	N/D	N/D	0.0005	No standard
n-Propylbenzene	N/D	N/D	N/D	0.005	No standard
n-Butylbenzene	N/D	N/D	N/D	0.005	No standard
Naphthalene	N/D	N/D	N/D	0.001	No standard
Hexachlorobutadiene	N/D	N/D	N/D	0.0005	No standard
1,3,5-Trimethylbenzene	N/D	N/D	N/D	0.0005	No standard
p-Isopropyltoluene	N/D	N/D	N/D	0.001	No standard
Isopropylbenzene	N/D	N/D	N/D	0.001	No standard
tert-Butylbenzene	N/D	N/D	N/D	0.001	No standard

*N/D indicates "None Detected"

Product>	Distilled Water	Drinking Water	Spring Water	Detection Limit	FDA SOQ
<u>Unregulated Contaminants</u>					
sec-Butylbenzene	N/D	N/D	N/D	0.001	No standard
Fluorotrchloromethane	N/D	N/D	N/D	0.0005	No standard
Dichlorodifluoromethane	N/D	N/D	N/D	0.0005	No standard
Bromochloromethane	N/D	N/D	N/D	0.0005	No standard

Product>	Distilled Water	Drinking Water	Spring Water	Detection Limit	FDA SOQ
<u>Other Regulated Contaminants</u>					

*N/D indicates "None Detected"